



中国国家强制性产品认证证书

证书编号: 2015010304806588

委托人名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产者(制造商)名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称、地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

软起动器

PSTX470-600-70, PSTX570-600-70, PSTX470-690-70, PSTX570-690-70; 详细参数及型号解释见附件

产品标准和技术要求

GB/T 14048.6-2016;

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2018 年 03 月 08 日 有效期至: 2020 年 09 月 23 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2015 年 09 月 23 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2015010304806588

NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co., Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Soft Starters
PSTX470-600-70, PSTX570-600-70, PSTX470-690-70, PSTX570-690-70; See the appendix
x

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016;

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Mar.08,2018

Valid until: Sep.23,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.23,2015

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2015010304806588

纸 号: 1917086

PSTX470-600-70, PSTX570-600-70,
 PSTX470-690-70, PSTX570-690-70;
 PSTX470-600-70, PSTX570-600-70,
 $U_i: 600V; U_e: 208-550V AC$;
 $I_{th} = I_e: 470A (PSTX470-600-70)$;
 $570A (PSTX570-600-70)$
 PSTX470-690-70, PSTX570-690-70
 $U_i: 690V; U_e: 208-690V AC$;
 $I_{th} = I_e: 470A (PSTX470-690-70)$;
 $570A (PSTX570-690-70)$

Pe:

产品型号	额定工作 电 流 I_e (A)	额定功率(kW)			
		220-230V	380-400V	500V	690V
PSTX470-600-70	470	132	250	315	-
PSTX570-600-70	570	160	315	400	-
PSTX470-690-70	470	132	250	315	450
PSTX570-690-70	570	160	315	400	560

AC-53a; 3P

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2015010304806588

纸 号: 1917086

型号解释:

$\frac{\text{PSTX}}{1} \frac{\text{***}}{2} - \frac{\text{***}}{3} - \frac{70}{4}$

1 = Softstarter, name of series

2 = Current rating, Inline Ie,: 470=470A, 570=570A

3 = Operational voltage, Ue: 600 = 208-550V AC, 690 = 208-690V AC

4 = Control supply voltage, Us: 70 = 100 - 250V AC

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心